

1. BUILDING WILL BE DESIGNED (STRUCTURES) AS PER RELEVANT IS CODES FOR EARTH QUAKE RESISTANCE.
2. THE BUILDING COMPLY WITH FIRE NORMS

LEGEND :-

SYM.	DESCRIPTION
① ○	100# SOIL & VENT PIPE
② ○	100# WASTE & VENT PIPE
③ ●	150# RAIN WATER PIPE
50 ●	100# RAIN WATER PIPE
④ ●	80#,65#,40# DOMESTIC WATER SUPPLY
⑤ ●	80#,65#,40# FLUSHING WATER SUPPLY
⑥ ●	75# ANTISIPHONAGE PIPE
⑦ ●	50# DOMESTIC WATER TANK FILLING
⑧ ●	40# DOMESTIC WATER TANK FILLING
⊞	KHURRA 450X450

LEGEND FOR FIRE FIGHTING	
F.H.C	FIRE HOSE CABINET
	PENDENT TYPE SPRINKLER MINIMUM INLET 20mmØ
	CO2 TYPE FIRE EXTINGUISHER CAPACITY=4.5Kg
	UPRIGHT TYPE SPRINKLER MINIMUM INLET 20mmØ

PROPOSED COMMERCIAL COLONY AREA
MEASURING 2.961 ACRES. (LICENCE NO.
10 OF 2010 DATED 29-12-2010) IN
SECTOR-82-A, GURGAON MANESAR
URBAN COMPLEX BEING DEVELOPED
BY SH. TEJPAL S/O SH. BADAM SINGH AND
SMT. SAKUNTALA DEVI W/O SH. TEJPAL IN
COLLABORATION WITH M/S VATIKA LTD.

Associate Architects

R | S | M | S
ARCHITECTS

RSMS ARCHITECTS PVT. LTD.
9, Nora Niwas Bhawani Kunj
Behind D2), Vasant Kunj,
New Delhi-110070.
Tel.: 011-26898616, 26898617
www.rsms-arch.com

~~D. T. (HQ)~~
~~Member Secretary~~
~~B.E.~~


F
S.T.P. (G)
Member S.P.C.

Fredly
G.T.P. (H)
Chairman B.E.

Checked and found ok for Public Health
(Internal) Services only subject to comments in
forwarding letter No. SE(HQ) 231 St. 501-1

Superintending Engineer (HQ)
Hillier, Penchikule

ARCHITECT'S SEAL
& SIGNATURE

OWNER'S SEAL
& SIGNATURE

For YATTA LIMITED
(*[Signature]*)
Authorised Signatory

JULY-2011

Scale : 1:100

Drawing Title:—

rawing No:—

8TH & 9TH
FLOOR PLAN
(BLOCK-D)

D-03